




Compare the Performance . . .
. . . Measure the Difference

OptiPure QT & FX System Sizing Guide for Scotsman Ice Machines

It is common for ice machine manufacturers to size equipment in food service applications to operate approximately 18 hours per day. Recommendations are based on providing the most cost effective and efficient method of delivering the amount of ice needed daily while meeting high demand periods such as lunch and dinner.

The same logic applies when selecting the right water treatment system. NSF Certified capacities of the recommended OptiPure systems meet or exceed ice machine water usage requirements over a six-month period. System flow rates exceed manufacturers required flow rate for proper operation of equipment.



OptiPure filtration systems for ice machines contain IsoNet scale and corrosion technology. IsoNet isolates and evenly distributes media through the core of the filter. This maximizes media contact time with water and provides consistent dosing over a six-month period between filter changes.

* FXI-22, FX+ and QT+ models include 20" sediment prefilters for water supplies with high levels of silt/sediment.



QTCI models are NSF Certified for Cyst and Turbidity reduction.

		FX Value		QT Filters with A-Tough		Scotsman		Ice Production 24-hrs. @ 90/70°	Water Usage** 6-months @ 90/70°	Ice Production 24-hrs. @ 70/50°	Water Usage** 6-months @ 70/50°
FXI-11	QTI-1 QTCI-1	CME 256	240	5,184	307	6,631					
		CME 306	260	6,985	340	9,134					
		CME 456	420	8,732	480	9,974					
		CME 506	395	7,999	500	10,125					
		CME 656	583	11,806	705	14,276					
		CME 806	660	11,494	770	13,410					
FXI-12 *FXI-22	QTI-2 *QTI-2+	CME 1056	800	16,740	975	20,402					
		CME 1356	1,145	24,732	1,400	30,240					
FXI-22P *FXI-22P+	QTCI-2 *QTCI-2+	CME 1656	1,250	27,000	1,600	34,560					
		CME 1856	1,695	36,841	1,825	39,667					
		CME 2006	1,740	41,108	1,930	45,596					

**Water usage over a six-month period is based upon an average machine run-time of 18 hours per day.